

**From:** Gourley, Chris L (DFW)  
**Sent:** Monday, November 05, 2012 8:39 AM  
**To:** Mendoza, Sonia (ECY); Cornett, Deborah (ECY); Groven, Connie (ECY)  
**Cc:** SEPADesk2 (DFW)  
**Subject:** RE: ECY 12-5039 - Bogachiel Access Area Asphalt Overlay project - Comments

Ms. Mendoza, Ms. Groven, and Ms. Cornett,

Thank you for your comments on SEPA number 12-5039 for the Bogachiel Access Area Asphalt Overlay Project. In response to your comments, please see below:

**Toxics Cleanup:** If contamination is suspected, discovered, or occurs during the project, WDFW shall test the potentially contaminated media. If the media is found to be contaminated, WDFW will notify Ecology's Environmental Report Tracking System Coordinator at the Southwest Regional Office.

**Water Quality:** Erosion control measures will be in place prior to any clearing, grading, or constructions including, but not limited to, those shown on the plans. The controls will be effective to prevent stormwater runoff from carrying soil and other pollutants into surface water or stormdrains that lead to waters of the state. WDFW will take into consideration Ecology's recommendation for stormwater treatment device installation so that any discharge will be appropriately treated to remove harmful substances. Proper disposal of construction debris will be on land in such a manner that debris will not enter water of the state and stormdrains draining to waters of the state and will not cause water quality degradation of state waters. Clearing limits will be clearly identified prior to any start of work. All cleared areas will be stabilized with either vegetation or other permanent stabilization.

Again, I thank you for your review of the project.

*Chris Gourley*

Biologist  
Capital and Asset Management Program  
Washington Department of Fish & Wildlife  
(360) 902-8392